

FireSilx Artificial Bark

BS EN 13501-1

FR CERTIFICATION

Standard:	BS EN 13501-1:2009
Standard Description:	Fire classification of construction products and building elements
Sample:	Bespoke Tree Artificial Bark
Date Tested:	19/01/2016
Classification/Result:	Class B, s2, d0
Classification Jurisdiction:	UK & Europe
Test Report Ref:	FR035
Test Report No:	65449

Mark Nesbitt



FireSilx Managing Director



Flame retardant properties of all FireSilx products are guaranteed for life

Any duplication, whether in part or in full, is a breach of intellectual property rights and constitutes copyright infringement.
Copyright © FireSilx Company No SC156162