

FireSilx Artificial Foliage

BS EN 13501-1

FR CERTIFICATION

Standard: BS EN 13501-1:2018

Standard Description: Fire classification of construction products and building elements

Sample: FireSilx IFR Fabric Material

Date Tested: 31/10/2025

Classification/Result: Class B, s2, d0

Classification Jurisdiction: UK & Europe

Test Report Ref: FR046

Test Report No: SDFTS25006682R01_EN

Mark Nesbitt



FireSilx Managing Director



Flame retardant properties of all FireSilx products are guaranteed for life

Any duplication, whether in part or in full, is a breach of intellectual property rights and constitutes copyright infringement.
Copyright © FireSilx Company No SC156162